

\*\*HISTORICAL\*\*

# Sprinklers, Automatic and Open

## COMPANY

Zhejiang Youtaike Fire Equipment Co.,Ltd

No.11 FENGDA ROAD, TAOZHU STR, ZHUJI CITY

SHAOXING, ZHEJIANG 311801 China

EX27060

Sprinkler Identification Number (SIN) Ut0001,Ut0002,Ut0003,Ut0004,Ut0005,Ut0006,Ut0007 , Ut0008, Ut0009 and Ut0010 Glass Bulb Type.

### UPRIGHT AND PENDENT STANDARD-SPRAY SPRINKLERS NOMINAL 5.6 K-FACTOR

SIN	Response Type	Type	System Working Pressure, psig	Temp Rating, °F
Ut0003	SR	Upright	175	135, 155, 175, 200, 286
Ut0004	QR	Upright	175	135, 155, 175, 200, 286
Ut0005	SR	Pendent	175	135, 155, 175, 200, 286
Ut0006	QR	Pendent	175	135, 155, 175, 200, 286

### STANDARD SIDEWALL-SPRAY SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	System Working Pressure, psig	Temp Rating, °F
Ut0001*#	SR	Horizontal	5.6	175	135, 155, 175, 200, 286
Ut0002*#	QR	Horizontal	5.6	175	135, 155, 175, 200, 286

\* - Installed 4 to 12 in. below ceiling.

# - For ordinary hazard occupancies.

### CONVENTIONAL (OLD STYLE) SPRINKLERS

SIN	Response Type	Nom K-Factor	Temp Rating, °F
Ut0007	SR	5.6	135, 155, 175, 200, 286
Ut0008	QR	5.6	135, 155, 175, 200, 286

### FLUSH, RECESSED AND CONCEALED SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	System Working Pressure, psig	Temp Rating, °F	
					Cover	Sprinkler
Ut0009	SR	Conc. Pendent	5.6	175	135	135, 155
Ut0009	SR	Conc. Pendent	5.6	175	165	175, 200
Ut0010	QR	Conc. Pendent	5.6	175	135	135, 155
Ut0010	QR	Conc. Pendent	5.6	175	165	175, 200

Trademark and/or Tradename: **UT / UTEC , UTEC**

Last Updated on 2023-12-20

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."